


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:120.2V I:0.1870A P:22.25W PF:0.9905 Lamp Flux:1552.88x2 lm		
NAME: LOC-24TROF-DMWMCCT	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:1186*145mm	PROTECTION ANGLE:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 139.56 lm/W			
MODEL		I _{max} (cd)	1041	S/MH (C0/180)	1.25
NOMINAL POWER(W)	24	LOR(%)	100.0	S/MH (C90/270)	1.28
RATED VOLTAGE(V)	120-277	TOTAL FLUX (lm)	3105.8	η UP,DN (C0-180)	0.0,48.8
NOMINAL FLUX (lm)	1552.88	CIE CLASS	DIRECT	η UP,DN (C180-360)	0.0,51.2
LAMPS INSIDE	2	η up (%)	0.0	CIBSE SHR NOM	1.25
TEST VOLTAGE (V)	120	η down (%)	100.0	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators:
 Test Date: 2020-05-23

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity: 50%
 Test Distance: 8.600m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
5	1032	1019	1017	1023	1038	1027	1022	1023	0- 5	24.63	24.63	0.79,0.79
10	1013	992.9	993.8	1001	1024	1008	1005	1001	5- 10	72.49	97.12	3.13,3.13
15	984.1	962.0	970.5	973.5	1001	984.1	987.0	973.9	10- 15	117.5	214.6	6.91,6.91
20	946.2	926.8	947.3	941.8	967.8	955.7	969.2	943.0	15- 20	158.6	373.1	12,12
25	899.6	888.2	924.0	906.1	925.2	923.0	951.5	908.2	20- 25	195.0	568.1	18.3,18.3
30	846.0	846.3	867.8	867.2	875.0	887.2	897.6	870.7	25- 30	225.1	793.2	25.5,25.5
35	785.6	794.6	811.5	817.3	816.9	839.6	843.7	822.1	30- 35	246.6	1040	33.5,33.5
40	720.1	725.0	755.3	749.2	752.6	772.2	789.9	754.3	35- 40	259.9	1300	41.8,41.8
45	649.5	655.1	699.1	680.3	683.1	704.2	736.0	686.2	40- 45	265.3	1565	50.4,50.4
50	575.4	585.7	642.9	611.6	608.5	636.0	682.2	618.6	45- 50	263.3	1828	58.9,58.9
55	497.8	517.6	578.5	543.3	529.8	568.9	617.2	552.1	50- 55	253.9	2082	67,67
60	417.4	450.0	514.2	475.6	447.6	501.6	552.2	486.3	55- 60	237.2	2319	74.7,74.7
65	335.1	377.6	449.9	403.5	362.8	426.6	487.1	415.0	60- 65	214.5	2534	81.6,81.6
70	252.6	308.0	385.6	333.8	276.5	353.5	422.1	346.2	65- 70	186.9	2721	87.6,87.6
75	172.2	240.9	321.2	266.4	190.4	282.9	357.1	279.8	70- 75	155.8	2877	92.6,92.6
80	98.06	173.6	218.6	197.2	112.2	210.2	251.3	212.0	75- 80	119.9	2997	96.5,96.5
85	40.19	92.39	116.0	104.3	49.38	113.5	145.5	122.9	80- 85	76.70	3073	99,99
90	8.629	13.00	13.38	12.94	13.61	18.68	39.64	35.48	85- 90	32.39	3106	100,100
95									90- 95			
100									95-100			
105									100-105			
110									105-110			
115									110-115			
120									115-120			
125									120-125			
130									125-130			
135									130-135			
140									135-140			
145									140-145			
150									145-150			
155									150-155			
160									155-160			
165									160-165			
170									165-170			
175									170-175			
180									175-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:
 Test Date:2020-05-23

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity:50%
 Test Distance:8.600m [K=1.0000]
 Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

pcc	80%			70%			50%			30%			10%			0
p _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
p _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	.00
1.0	1.02	.98	.93	1.00	.96	.92	.96	.92	.89	.92	.89	.86	.88	.86	.84	.82
2.0	.89	.81	.75	.87	.80	.74	.83	.77	.72	.80	.75	.71	.77	.73	.69	.67
3.0	.77	.69	.62	.76	.68	.61	.73	.66	.60	.70	.64	.59	.67	.62	.58	.56
4.0	.68	.59	.52	.67	.58	.52	.64	.57	.51	.62	.56	.50	.60	.54	.50	.47
5.0	.61	.52	.45	.60	.51	.44	.58	.50	.44	.56	.49	.43	.54	.48	.43	.41
6.0	.55	.46	.39	.54	.45	.39	.52	.44	.38	.50	.43	.38	.49	.42	.38	.36
7.0	.50	.41	.34	.49	.40	.34	.47	.39	.34	.46	.39	.34	.44	.38	.33	.31
8.0	.45	.37	.31	.45	.36	.30	.43	.36	.30	.42	.35	.30	.41	.34	.30	.28
9.0	.41	.33	.27	.41	.33	.27	.40	.32	.27	.39	.32	.27	.38	.31	.27	.25
10.0	.38	.30	.25	.38	.30	.25	.37	.30	.25	.36	.29	.25	.35	.29	.24	.23



C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators:
 Test Date: 2020-05-23

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity: 50%
 Test Distance: 8.600m [K=1.0000]
 Remarks:

WEC AND CCEC

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.338	.192	.061	.331	.189	.060	.317	.182	.058	.305	.176	.056	.294	.170	.055		
2.0	.310	.170	.052	.303	.167	.051	.292	.162	.050	.281	.157	.049	.271	.153	.048		
3.0	.283	.150	.045	.277	.148	.045	.267	.144	.044	.257	.141	.043	.248	.137	.042		
4.0	.258	.134	.039	.254	.133	.039	.244	.130	.039	.236	.127	.038	.228	.124	.038		
5.0	.237	.121	.035	.233	.120	.035	.225	.117	.034	.217	.115	.034	.210	.112	.034		
6.0	.219	.110	.031	.215	.109	.031	.208	.107	.031	.201	.104	.031	.195	.102	.030		
7.0	.203	.100	.028	.200	.100	.028	.193	.098	.028	.187	.096	.028	.181	.094	.028		
8.0	.189	.092	.026	.186	.092	.026	.180	.090	.026	.175	.089	.026	.170	.087	.025		
9.0	.177	.086	.024	.174	.085	.024	.169	.084	.024	.164	.082	.024	.159	.081	.023		
10.0	.166	.080	.022	.164	.079	.022	.159	.078	.022	.154	.077	.022	.150	.076	.022		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.182	.156	.132	.156	.134	.114	.107	.092	.079	.061	.053	.046	.020	.017	.015	
2.0	.175	.132	.096	.150	.113	.083	.103	.079	.058	.059	.046	.034	.019	.015	.011	
3.0	.167	.114	.073	.143	.099	.063	.098	.069	.044	.057	.040	.026	.018	.013	.009	
4.0	.159	.101	.057	.137	.087	.049	.094	.061	.035	.054	.036	.021	.017	.012	.007	
5.0	.151	.091	.046	.130	.079	.040	.090	.055	.028	.052	.032	.017	.017	.011	.006	
6.0	.144	.083	.038	.124	.071	.033	.085	.050	.024	.050	.029	.014	.016	.010	.005	
7.0	.137	.076	.033	.118	.066	.028	.081	.046	.020	.047	.027	.012	.015	.009	.004	
8.0	.130	.070	.028	.112	.061	.025	.078	.043	.017	.045	.025	.010	.015	.008	.003	
9.0	.124	.065	.025	.107	.056	.022	.074	.040	.015	.043	.023	.009	.014	.008	.003	
10.0	.118	.061	.022	.102	.053	.019	.071	.037	.014	.041	.022	.008	.013	.007	.003	

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:
 Test Date:2020-05-23

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity:50%
 Test Distance:8.600m [K=1.0000]
 Remarks:

UGR(Unified Glare Rating) Table

ceiling/cavity		0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls		0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane		0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions		Viewed crosswise					Viewed endwise				
x = 2H y = 2H		13.0	14.6	13.3	14.8	15.0	14.0	15.6	14.3	15.8	16.0
	3H	14.4	15.9	14.7	16.1	16.4	16.1	17.5	16.4	17.8	18.0
	4H	15.0	16.4	15.3	16.6	16.9	17.2	18.5	17.5	18.8	19.1
	6H	15.3	16.6	15.7	16.9	17.2	18.0	19.3	18.4	19.6	19.9
	8H	15.4	16.7	15.8	17.0	17.3	18.4	19.6	18.7	19.9	20.2
	12H	15.5	16.7	15.8	17.0	17.3	18.6	19.9	19.0	20.2	20.5
4H	2H	13.8	15.2	14.1	15.4	15.7	14.6	15.9	14.9	16.2	16.5
	3H	15.4	16.6	15.8	16.9	17.2	16.9	18.1	17.2	18.4	18.7
	4H	16.1	17.2	16.5	17.5	17.9	18.1	19.2	18.5	19.5	19.9
	6H	16.6	17.6	17.0	17.9	18.3	19.2	20.2	19.6	20.5	20.9
	8H	16.7	17.7	17.1	18.0	18.4	19.6	20.5	20.0	20.9	21.3
	12H	16.8	17.7	17.2	18.1	18.5	19.9	20.8	20.4	21.2	21.6
8H	4H	16.6	17.6	17.0	17.9	18.3	18.4	19.3	18.8	19.7	20.1
	6H	17.3	18.1	17.8	18.5	19.0	19.6	20.4	20.1	20.8	21.3
	8H	17.6	18.3	18.0	18.7	19.2	20.2	20.9	20.7	21.3	21.8
	12H	17.8	18.4	18.2	18.8	19.3	20.7	21.3	21.2	21.7	22.2
12H	4H	16.7	17.6	17.2	18.0	18.4	18.4	19.2	18.8	19.6	20.0
	6H	17.5	18.2	18.0	18.7	19.1	19.7	20.4	20.2	20.8	21.3
	8H	17.9	18.5	18.4	18.9	19.4	20.3	20.9	20.8	21.4	21.9
Variations with the observer position at spacings:											
S = 1.0H		+ 0.2 / - 0.2					+ 0.1 / - 0.1				
1.5H		+ 0.2 / - 0.2					+ 0.1 / - 0.2				
2.0H		+ 0.1 / - 0.2					+ 0.1 / - 0.3				

CIE Pub.117 Corrected 3106 lm Total Lamp Luminous Flux. (8log(F/F0) = 3.9)

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators:
 Test Date: 2020-05-23

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity: 50%
 Test Distance: 8.600m [K=1.0000]
 Remarks:

UTILIZATION FACTORS TABLE

REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	56	44	37	55	44	37	54	44	37	30
0.80	66	54	46	65	54	46	63	53	46	39
1.00	74	63	55	73	62	55	71	64	54	47
1.25	81	70	63	80	69	62	77	68	62	54
1.50	86	76	68	85	75	68	81	73	67	59
2.00	93	84	77	91	83	76	88	81	75	67
2.50	97	89	83	95	88	82	91	85	80	71
3.00	101	93	87	99	92	86	94	89	84	75
4.00	105	99	94	103	97	92	98	94	90	81
5.00	108	102	98	105	100	96	100	97	93	84
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators:
 Test Date: 2020-05-23

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity: 50%
 Test Distance: 8.600m [K=1.0000]
 Remarks:


ISOCANDELA DIAGRAM

Conical surface Flux(90deg):

1565.1 lm
%lum = 50.4%
%lamp = 50.4%


Conical surface Flux(120deg):

2319.5 lm
%lum = 74.7%
%lamp = 74.7%



C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature:25DEG
Operators:
Test Date:2020-05-23

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:


AAI Figure

Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature:25DEG
Operators:
Test Date:2020-05-23

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

ISOLUX DIAGRAM



C Range: 0 - 360DEG	γ Range: 0 - 90DEG
C Interval: 5.0DEG	γ Interval: 0.5DEG
Test Speed: HIGH	Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Temperature:25DEG	Humidity:50%
Operators:	Test Distance:8.600m [K=1.0000]
Test Date:2020-05-23	Remarks:

LED Avg.L Report

Test:U:120.2V I:0.1870A P:22.25W PF:0.9905 Lamp Flux:1552.88x2 lm		
NAME: LOC-24TROF-DMWMCCT	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:1186*145mm	PROTECTION ANGLE:


AvgL	cd/m2
L_0~180 (65) av	1147
L_0~180 (75) av	973
L_0~180 (85) av	714
L_90~270 (65) av	1540
L_90~270 (75) av	1820
L_90~270 (85) av	2083
L_45 (65) av	1333
L_45 (75) av	1435
L_45 (85) av	1725

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:
 Test Date:2020-05-23

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity:50%
 Test Distance:8.600m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-05-23

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity: 50%
Test Distance: 8.600m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--1

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-05-23

```

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

```

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--2

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-05-23

```

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

```

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--3

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-05-23

```

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

```

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--4

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-05-23

```

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

```