


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:120.1V I:0.1885A P:22.58W PF:0.9975 Lamp Flux:3343.54x1 lm		
NAME: LOC-14TROF-DMWMCCT	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:1186*95	PROTECTION ANGLE:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 148.08 lm/W			
MODEL		I _{max} (cd)	1069	S/MH (C0/180)	1.23
NOMINAL POWER(W)	24	LOR(%)	100.0	S/MH (C90/270)	1.32
RATED VOLTAGE(V)	120-277	TOTAL FLUX(lm)	3343.5	η UP,DN(C0-180)	0.0,49.2
NOMINAL FLUX(lm)	3343.54	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,50.8
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM	1.25
TEST VOLTAGE (V)	120	η down (%)	100.0	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:
 Test Date:2020-03-12

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity:50%
 Test Distance:8.600m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
5	1062	1052	1050	1053	1064	1056	1053	1054	0- 5	25.35	25.35	0.76,0.76
10	1043	1029	1031	1032	1048	1038	1038	1034	5- 10	74.75	100.1	2.99,2.99
15	1014	1002	1013	1006	1022	1014	1023	1009	10- 15	121.4	221.5	6.62,6.62
20	975.0	970.4	993.9	974.8	984.4	985.3	1007	978.7	15- 20	164.2	385.6	11.5,11.5
25	926.3	934.7	975.2	938.9	937.5	952.4	992.1	944.6	20- 25	202.3	587.9	17.6,17.6
30	869.8	895.8	928.6	899.6	882.3	916.0	947.0	907.2	25- 30	234.2	822.1	24.6,24.6
35	806.4	847.7	882.1	851.0	819.8	869.6	901.9	860.0	30- 35	257.9	1080	32.3,32.3
40	737.4	784.2	835.5	787.4	751.3	806.8	856.8	796.7	35- 40	273.7	1354	40.5,40.5
45	664.1	720.2	788.9	723.2	678.1	743.2	811.7	733.0	40- 45	281.9	1636	48.9,48.9
50	587.5	656.6	742.3	659.6	601.2	680.0	766.6	669.7	45- 50	283.0	1919	57.4,57.4
55	509.1	594.3	666.2	597.0	521.9	618.0	693.4	607.8	50- 55	276.3	2195	65.6,65.6
60	429.8	531.0	590.2	533.0	441.6	554.8	620.2	545.0	55- 60	260.4	2455	73.4,73.4
65	350.8	451.2	514.2	450.6	361.1	474.5	547.0	466.3	60- 65	237.5	2693	80.5,80.5
70	273.1	374.8	438.1	371.4	282.0	397.5	473.9	391.2	65- 70	209.2	2902	86.8,86.8
75	197.6	301.7	362.1	295.5	203.9	323.9	400.7	319.6	70- 75	176.8	3079	92.1,92.1
80	126.1	226.2	246.0	217.9	131.0	246.6	275.7	244.3	75- 80	138.5	3217	96.2,96.2
85	59.75	119.1	130.0	114.9	63.84	132.9	150.7	132.2	80- 85	89.87	3307	98.9,98.9
90	9.171	13.81	13.96	13.65	14.05	20.84	25.74	21.73	85- 90	36.38	3344	100,100
95									90- 95			
100									95-100			
105									100-105			
110									105-110			
115									110-115			
120									115-120			
125									120-125			
130									125-130			
135									130-135			
140									135-140			
145									140-145			
150									145-150			
155									150-155			
160									155-160			
165									160-165			
170									165-170			
175									170-175			
180									175-180			
DEG	LUMINOUS INTENSITY:cd								UNIT:lm			

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:
 Test Date:2020-03-12

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity:50%
 Test Distance:8.600m [K=1.0000]
 Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

pcc	80%			70%			50%			30%			10%			0
p _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
p _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.02	.97	.93	.90	.95	.91	.95	.92	.88	.91	.88	.86	.88	.85	.83	.81
2.0	.88	.81	.74	.86	.79	.73	.82	.77	.72	.79	.74	.70	.76	.72	.68	.66
3.0	.77	.68	.61	.75	.67	.60	.72	.65	.59	.69	.63	.58	.67	.62	.57	.55
4.0	.68	.58	.51	.66	.58	.51	.64	.56	.50	.61	.55	.49	.59	.53	.49	.46
5.0	.60	.51	.44	.59	.50	.44	.57	.49	.43	.55	.48	.43	.53	.47	.42	.40
6.0	.54	.45	.38	.53	.44	.38	.51	.43	.37	.50	.42	.37	.48	.42	.37	.35
7.0	.49	.40	.33	.48	.39	.33	.47	.39	.33	.45	.38	.33	.44	.37	.33	.30
8.0	.45	.36	.30	.44	.35	.30	.43	.35	.29	.41	.34	.29	.40	.34	.29	.27
9.0	.41	.32	.27	.40	.32	.27	.39	.32	.26	.38	.31	.26	.37	.31	.26	.24
10.0	.38	.30	.24	.37	.29	.24	.36	.29	.24	.35	.29	.24	.34	.28	.24	.22



C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators:
 Test Date: 2020-03-12

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity: 50%
 Test Distance: 8.600m [K=1.0000]
 Remarks:

WEC AND CCEC

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)									
0.0																
1.0	.345	.196	.062	.338	.193	.061	.324	.186	.059	.312	.180	.058	.301	.174	.056	
2.0	.315	.173	.053	.309	.170	.052	.297	.165	.051	.286	.160	.050	.276	.156	.049	
3.0	.287	.153	.046	.281	.151	.045	.271	.147	.045	.261	.143	.044	.252	.140	.043	
4.0	.262	.136	.040	.257	.134	.040	.248	.131	.039	.239	.128	.039	.231	.125	.038	
5.0	.240	.122	.035	.236	.121	.035	.227	.118	.035	.220	.116	.034	.213	.114	.034	
6.0	.221	.111	.032	.217	.110	.032	.210	.108	.031	.203	.106	.031	.197	.104	.031	
7.0	.205	.101	.029	.202	.100	.029	.195	.099	.028	.189	.097	.028	.183	.095	.028	
8.0	.191	.093	.026	.188	.092	.026	.182	.091	.026	.176	.089	.026	.171	.088	.026	
9.0	.178	.086	.024	.176	.086	.024	.170	.084	.024	.165	.083	.024	.161	.082	.024	
10.0	.167	.080	.022	.165	.080	.022	.160	.078	.022	.155	.077	.022	.151	.076	.022	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.183	.156	.132	.156	.134	.113	.107	.092	.078	.062	.053	.046	.020	.017	.015	
2.0	.175	.132	.095	.150	.113	.082	.103	.078	.057	.059	.046	.034	.019	.015	.011	
3.0	.168	.114	.072	.144	.099	.062	.099	.069	.044	.057	.040	.026	.018	.013	.008	
4.0	.160	.101	.056	.137	.088	.049	.094	.061	.035	.055	.036	.020	.018	.012	.007	
5.0	.152	.091	.046	.131	.079	.040	.090	.055	.028	.052	.032	.017	.017	.011	.005	
6.0	.145	.083	.038	.125	.072	.033	.086	.050	.023	.050	.029	.014	.016	.010	.005	
7.0	.138	.076	.032	.119	.066	.028	.082	.046	.020	.048	.027	.012	.015	.009	.004	
8.0	.131	.070	.028	.113	.061	.024	.078	.043	.017	.045	.025	.010	.015	.008	.003	
9.0	.125	.065	.025	.107	.056	.022	.074	.040	.015	.043	.023	.009	.014	.008	.003	
10.0	.119	.061	.022	.102	.053	.019	.071	.037	.014	.041	.022	.008	.013	.007	.003	

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:
 Test Date:2020-03-12

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity:50%
 Test Distance:8.600m [K=1.0000]
 Remarks:

UGR(Unified Glare Rating) Table

ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	19.7	21.3	20.0	21.5	21.7	21.2	22.8	21.5	23.0	23.2
3H	21.3	22.7	21.6	23.0	23.2	23.3	24.7	23.6	25.0	25.2
4H	21.9	23.3	22.2	23.6	23.8	24.3	25.7	24.6	26.0	26.2
6H	22.4	23.7	22.7	24.0	24.3	25.2	26.5	25.5	26.8	27.1
8H	22.6	23.9	22.9	24.1	24.4	25.5	26.8	25.9	27.1	27.4
12H	22.7	23.9	23.1	24.2	24.5	25.8	27.0	26.1	27.3	27.6
4H 2H	20.7	22.1	21.0	22.4	22.6	21.8	23.2	22.1	23.4	23.7
3H	22.5	23.7	22.8	24.0	24.3	24.1	25.3	24.4	25.6	25.9
4H	23.2	24.4	23.6	24.7	25.0	25.3	26.4	25.7	26.8	27.1
6H	23.9	24.9	24.3	25.3	25.6	26.4	27.4	26.8	27.7	28.1
8H	24.2	25.1	24.6	25.5	25.9	26.8	27.7	27.2	28.1	28.5
12H	24.3	25.2	24.8	25.6	26.0	27.1	28.0	27.5	28.4	28.8
8H 4H	23.9	24.9	24.3	25.2	25.6	25.6	26.6	26.1	27.0	27.4
6H	24.8	25.6	25.3	26.0	26.5	26.9	27.7	27.4	28.1	28.5
8H	25.2	25.9	25.7	26.4	26.8	27.5	28.2	27.9	28.6	29.0
12H	25.6	26.2	26.0	26.6	27.1	27.9	28.5	28.4	29.0	29.5
12H 4H	24.0	24.9	24.5	25.3	25.7	25.7	26.5	26.1	26.9	27.3
6H	25.1	25.8	25.5	26.2	26.7	27.0	27.7	27.5	28.1	28.6
8H	25.6	26.2	26.0	26.6	27.1	27.6	28.2	28.1	28.7	29.2
Variations with the observer position at spacings:										
S = 1.0H	+ 0.1 / - 0.1					+ 0.1 / - 0.1				
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.2				
2.0H	+ 0.1 / - 0.3					+ 0.2 / - 0.3				

CIE Pub.117 Corrected 3344 lm Total Lamp Luminous Flux. (8log(F/F0) = 4.2)

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators:
 Test Date: 2020-03-12

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity: 50%
 Test Distance: 8.600m [K=1.0000]
 Remarks:

UTILIZATION FACTORS TABLE

REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	55	43	36	55	43	36	53	43	36	29
0.80	65	53	45	64	53	45	62	52	45	38
1.00	73	62	54	72	61	54	70	63	53	46
1.25	80	69	62	79	69	61	76	67	60	53
1.50	86	75	67	84	74	67	81	72	66	58
2.00	93	83	76	91	82	76	87	80	74	66
2.50	97	88	82	95	87	81	91	84	79	70
3.00	100	93	87	98	91	86	94	88	83	75
4.00	105	98	93	102	97	92	98	93	89	80
5.00	107	102	97	105	100	96	100	96	93	83
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature: 25DEG
 Operators:
 Test Date: 2020-03-12

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity: 50%
 Test Distance: 8.600m [K=1.0000]
 Remarks:


ISOCANDELA DIAGRAM

Conical surface Flux(90deg):

1635.6 lm
%lum = 48.9%
%lamp = 48.9%

Conical surface Flux(120deg):


2455.3 lm
%lum = 73.4%
%lamp = 73.4%



C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature:25DEG
Operators:
Test Date:2020-03-12


γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

AAI Figure



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

ISOLUX DIAGRAM



C Range: 0 - 360DEG	γ Range: 0 - 90DEG
C Interval: 5.0DEG	γ Interval: 0.5DEG
Test Speed: HIGH	Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Temperature:25DEG	Humidity:50%
Operators:	Test Distance:8.600m [K=1.0000]
Test Date:2020-03-12	Remarks:

LED Avg.L Report

Test:U:120.1V I:0.1885A P:22.58W PF:0.9975 Lamp Flux:3343.54x1 lm		
NAME: LOC-14TROF-DMWMCCT	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:
MFR.:	SUR.:1186*95	PROTECTION ANGLE:


AvgL	cd/m2
L_0~180 (65) av	7476
L_0~180 (75) av	6885
L_0~180 (85) av	6293
L_90~270 (65) av	11143
L_90~270 (75) av	13078
L_90~270 (85) av	14293
L_45 (65) av	9674
L_45 (75) av	10636
L_45 (85) av	12708

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
 C Interval: 5.0DEG
 Test Speed: HIGH
 Temperature:25DEG
 Operators:
 Test Date:2020-03-12

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
 Humidity:50%
 Test Distance:8.600m [K=1.0000]
 Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-03-12

γ Range: 0 - 90DEG
 γ Interval: 0.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity: 50%
Test Distance: 8.600m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--1

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-03-12

```

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

```

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--2

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-03-12

```

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

```

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--3

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-03-12

```

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

```

LUMINOUS DISTRIBUTION INTENSITY DATA

Table--4

UNIT: cd

[illegible]

C Range: 0 - 360DEG
C Interval: 5.0DEG
Test Speed: HIGH
Temperature: 25DEG
Operators:
Test Date: 2020-03-12

```

γ Range: 0 - 90DEG
γ Interval: 0.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.290
Humidity:50%
Test Distance:8.600m [K=1.0000]
Remarks:

```